

April 28, 2010

PROCON-- PREMIER CONCRETE, INC  
MIKE DONOHUE  
8431 HIGHWAY 57  
BAILEYS HARBOR WI 54202

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: PROCON  
Product Name: SEPTIC/PUMP OR HOLDING (WAS 20050241)  
Model Number(s): 762 (SEPTIC OR PUMP) OR 811 (HOLDING)  
(36 IN. L.L., 21.0 GAL/IN., 84 IN. MAX. DEPTH OF BURY, 362 G.P.D. WHEN USED AS A  
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER; **TANK DIMENSIONS = 80 IN L X 66 IN W X 36 IN. H)**  
Product File No: 20100138

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JUNE 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into access cover.
  - Four inch inlet in tank cover for holding tanks only.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- Bedding: Place tanks a min. 4 in. of tampered bedding material of which 100% shall pass through ¾ in. screen. Sand, pea gravel, road gravel or ¾ in. screened stone is acceptable. In wet excavations, use min. 6 in. tampered bedding. Bedding shall be raked to allow ½ in. center depression. Extend bedding min. 6 in. on all sides of tank bottom.

This approval supersedes the approval issued on 4/26/2005 under product file number 20050241. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050241. **As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.** The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use. Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Review  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV